

Breiholz Construction 1527 Maine St Des Moines, IA, 50314 Phone: 515-288-6077 Web: www.breiholz.com

ESTIMATION

NO. PROJECT TASK DESCRIPTION

Framing and drywall 1 Finishes

CHANGE REQUEST

000025 Request Nbr. **Request Date** 20-Apr-2022 **Customer ID** 0806 Currency USD Project Nbr. 21-940

Contract Time Change, Days

Description ASI 46 Framing For

Revised Supply Air

LINE **AMT** 902.46

Chase

QTY UOM

1.00 LS

Approved Amount of Change (USD): 902.46

CONTRACTOR

Breiholz Construction 1527 Maine St Des Moines, IA, 50314 Phone: 515-288-6077 Web: www.breiholz.com

20-Apr-2022

Scott Rozenboom (signature)

OWNER

Marshall County

1 E Main St Marshalltown, IA, 50158

20-Apr-2022

(signature)



ARCHITECT'S SUPPLEMENTAL INSTRUCTION

PROJECT NAME: Marshall County Courthouse PROJECT NO: 18827003

CLIENT NAME: Marshall County DATE: 20 March 2022

ASI NO.: 046

PROJECT LOCATION: 1 E Main St. Marshalltown, IA 50158

GENERAL CONTRACTOR: Breiholz Construction Co. CONTACT: Jimi Peters

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgment that there will be no change in the Contract Sum or Contract Time.

Description:

Rerouting

Architectural drawings

- 1. A102 FLOOR PLAN LEVEL 2
 - a. ADD metal stud framing for revised supply air chase.
- 2. A103 FLOOR PLAN LEVEL 3
 - a. ADD metal stud framing for revised supply air chase.
- 3. A202 REFLECTED CEILING PLAN LEVEL 2
 - a. ADD metal stud framing for revised supply air chase.
- 4. A203 REFLECTED CEILING PLAN LEVEL 3
 - a. ADD metal stud framing for revised supply air chase.

Mechanical drawings

- 1. M101 FIRST FLOOR MECHANICAL PLAN
 - REVISE size and ADD extension to supply ductwork coming out of chimney near grids (B,11).
- 2. M102 SECOND FLOOR MECHANICAL PLAN
 - a. REVISE location of supply ductwork riser
- 3. M103 THIRD FLOOR MECHANICAL PLAN
 - a. REVISE location of supply ductwork riser

Associated Submittals/RFI's:

RFI 80 Attachments: (7) DRAWINGS